



ADDENDA

RFP TITLE: **Popkum Fire Hall Addition Engineering and Consulting Service**

RFP NUMBER: 26005

DATE ISSUED: February 27, 2026

1. Does the FVRD have drawing of the current building including mechanical plans, electrical diagrams and civil drawings?
 - *No*

2. Is the hall connected to natural gas?
 - *Yes*

3. Is the site connected to community water?
 - *Yes*

4. Does the site have a septic field?
 - *Yes*

5. Can you please confirm for me what occupancy classification the building will be designated as?
 - *Group D and Group F3*

6. Are you going to be revising or adding insulation to the existing building envelope that will remain?
 - *We will be removing and replacing the insulation in the existing wood frame section of the building. The existing 3 bay masonry building has no insulation.*

7. You mention airtightness testing “at beginning and end of the project”. Are you wanting a mid-construction airtightness test in addition to the required pre-occupancy test?
 - *Testing is required at the beginning and at the end of the project. Proponents may choose to test mid-way*