

February 1, 2024

Dear: Water System Operator

Re: Annual Reporting Requirements for Permitted Water Systems

Please find enclosed a copy of the 2023 Range Report for your water system. This report contains a summary of the bacteriological water quality results for the samples submitted through Fraser Health from your water system within the 2023 calendar year. As per the Drinking Water Protection Act the report is required to be made available to all users by June 30th 2024.

Please email HPLand@fraserhealth.ca if you would like to request a copy of the Annual Report Template.

The following are reminders for all water system operators:

- a) As drinking water testing has been deemed an essential service, all health units continue to remain open for sample drop-off on their regular designated days.
- b) Please do not use expired requisition forms as this will result in the samples either not being processed or results not being returned properly from the lab. Please discard all expired requisition forms. The expiration date is located on the bottom of the form.
- c) Please do not modify sample sites or other sections on the requisition forms. Key information is contained in the barcode and the lab is unable to include handwritten information. Please contact HPLand@fraserhealth.ca to request any changes to your requisition forms.
- d) Ensure the lead flush message provided is included with your Annual Report.
- e) The coding system from BCCDC has recently changed.

QRWRT indicates that the sample exceeded the 30 hour hold time. This could be due to courier issues or an incorrect date being recorded by the operator on the requisition forms. Water systems will still be given credit for the sample collected and a qualitative result is provided to Fraser Health. If there is bacteria detected, a separate email will be sent to the operator from Fraser Health.

REJCT DELAY3 indicates that the sample has been rejected as it has been too long in transit. No results will be provided for this sample.

Sincerely,

Drinking Water Program
Fraser Health Authority
HPLand@fraserhealth.ca

RECEIVED

FEB 08 2024

FRASER VALLEY REGIONAL DISTRICT
DEPARTMENT David R



fraserhealth

Better health.
Best in health care.

February 1, 2024

Water System Operators

Re: Metals in Drinking Water – “Flush” Message in Annual Reports

Fraser Health has recently revised its metals at the tap “Flush” message and we are asking all water systems to please include the following health message with your next annual reports to your users.

Anytime the water in a particular faucet has not been used for six hours or longer, “flush” your cold-water pipes by running the water until you notice a change in temperature. (This could take as little as five to thirty seconds if there has been recent heavy water use such as showering or toilet flushing. Otherwise, it could take two minutes or longer.) The more time water has been sitting in your home’s pipes, the more lead it may contain.

Use only water from the cold-tap for drinking, cooking, and especially making baby formula. Hot water is likely to contain higher levels of lead.

The two actions recommended above are very important to the health of your family. They will probably be effective in reducing lead levels because most of the lead in household water usually comes from the plumbing in your house, not from the local water supply.

Conserving water is still important. Rather than just running the water down the drain you could use the water for things such as watering your plants.

If you have any questions, please contact our Drinking Water Program at 604-870-7903.

Sincerely,

Drinking Water Program
Fraser Health Authority
HPLand@fraserhealth.ca

DRINKING WATER SYSTEM ANNUAL REPORT

Reporting Period: January 1st to December 31st, 2023 (year)

Water System Hope Airport

Water System Owner Fraser Valley Regional District

Primary Contact Name (Operator or Manager) Dave Roblin

Phone Number (Operator or Manager) 604-798-5426

E-mail (Operator or Manager) droblin@fvrd.ca

DESCRIBE YOUR WATER SUPPLY SYSTEM

What is the Source(s) of Raw Water?

Deep Well Shallow Well Surface Water Other

If other, specify details:

Does the Drinking Water System have Primary Disinfection? Yes No

Chlorination Ultraviolet Light Ozone Other

If other, specify details:

Does the Drinking Water System have Secondary Disinfection? Yes No

Chlorination Other

If other, specify details:

Does the Drinking Water System have Filtration? Yes No

Check all boxes that apply

Cartridge Filter(s) Carbon Filter Sand Filtration Reverse Osmosis Other

If other, specify details:

PUBLIC REPORTING

Emergency Response & Contingency Plan (ERCP)

Is your ERCP up to Date? Yes No

How do you Inform the System Users of the ERCP?

Hand Delivered Bulletin Board Newspaper Utility Bill Insert Website

Other (specify details)

Drinking Water System Annual Report

How do you Inform the System Users of the Annual Report? Utility Bill Insert Website

Hand Delivered Bulletin Board Newspaper

Other (specify details)

COMPLIANCE WITH OPERATING PERMIT

List the conditions that have been placed on your Operating Permit (if you have conditions, these will be stated on your permit):

Are you in compliance with the conditions listed on your Operating Permit? Yes No N/A

BACTERIOLOGICAL TESTING AND DRINKING WATER PROTECTION REGULATION WATER QUALITY STANDARDS

How many bacteriological samples were collected during this reporting period? 51

What is the minimum required sampling frequency for this system? {#samples/month} 4

Additional sampling details:

Was the minimum required sampling frequency achieved? Yes No

Comments:

Bacteriological summary attached to this report? Yes No

If no, how do the users of the system view the results?

WATER QUALITY STANDARDS FOR POTABLE WATER

Parameter:	Standard:	Did this system meet standard?	
Escherichia coli (for all samples)	No detectable Escherichia coli per 100ml	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Total Coliform Bacteria		<input checked="" type="checkbox"/>	
(if only 1 sample collected in a 30 day period)	No detectable total coliform bacteria per 100ml	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Total Coliform Bacteria	No more than 10% of samples contain total		
(if more than 1 sample collected in a 30 day period)	coliform bacteria, and No sample has more than 10 total coliform bacteria per 100ml	<input type="checkbox"/> Yes	<input type="checkbox"/> No

If the system did not meet any of above Drinking Water Protection Regulation standards, record the results in the table below; attach additional sheets if necessary.

Date	TC/100ml	E.coli/100ml	Reason	Corrective Action

CHEMICAL SAMPLING COMPLETED DURING THIS REPORTING PERIOD

Was any chemical sampling conducted during reporting period? Yes No

If no, when were the last chemical samples conducted (date) Don't Know Never Yes No
 If yes, did all water samples meet the Guidelines for Canadian Drinking Water Quality?

If any water samples did not meet the Guidelines for Canadian Drinking Water Quality, record the results in the table below; attach additional sheets if necessary.

Parameter	Result	Corrective Action /Treatment/ Comments

ADDITIONAL TESTING

Does the system have analyzers for continuous monitoring? Yes No

If yes, check all boxes that apply:

Chlorine Turbidity Other (details)

Are the results available on request?

If any additional testing or sampling was conducted, record results in the table below; attach additional sheets if necessary.

Additional Testing & Reason for Sampling	Corrective Action Taken

WATER QUALITY COMPLAINTS

Were there any water quality complaints in this reporting period? (e.g. taste; odour, colour etc.) Yes No

If yes, complete the table below; attach additional sheets if necessary.

Date	Water Quality Complaint	Corrective Action/ Treatment

OPERATIONAL PROBLEMS

Were there any operational problems during this reporting period? (e.g. insufficient water supply, malfunction of disinfection equipment, line breaks, elevated turbidity etc.). Yes No

If yes, complete the table below; attach additional sheets if necessary.

Incident Date	Type of Operational Problem	Corrective Action Taken

MAJOR UPGRADES/REPAIRS & EXPENSES

Were there any major upgrades/repairs or any major costs incurred during this reporting period? Yes No

If yes, complete the table below; attach additional sheets if necessary.

Major Upgrades/Expenses	Details
Improvements required by DWO	
Additions/changes to system	
Purchase or install new equipment	
Equipment repair or replacement	
Annual maintenance of system	flushing
Specialist report	
Other	

FUTURE IMPROVEMENTS

Are there any plans for future improvements? Yes No

If yes, complete the table below; attach additional sheets if necessary.

Future Upgrades or Improvements	Estimated Date of Completion

DATE COMPLETED: July 9 2024	COMPLETED BY: Dave Roblin
-----------------------------	---------------------------

Sample Range Report

Fraser Health Authority

Facility Name: Hope Airport WS
Date Range: Jan 1 2023 to Dec 31 2023

Operator Dave Roblin
45950 Cheam Ave
Chilliwack, BC V2P 1N6

Sampling Site	Date Collected	Total Coliform	E. Coli	Fecal Coliform
<u>Hope Airport Cafe,</u>				
<u>62724 Airport Rd</u>				
	1-3-2023 7:30:00 AM	LT1	LT1	
	1-10-2023 7:00:00 AM	LT1	LT1	
	1-17-2023 7:00:00 AM	LT1	LT1	
	1-24-2023 7:30:00 AM	LT1	LT1	
	1-31-2023 7:00:00 AM	LT1	LT1	
	2-7-2023 7:15:00 AM	LT1	LT1	
	2-14-2023 6:30:00 AM	LT1	LT1	
	2-21-2023 7:05:00 AM	LT1	LT1	
	2-28-2023 7:15:00 AM	LT1	LT1	
	3-7-2023 7:05:00 AM	LT1	LT1	
	3-14-2023 7:00:00 AM	LT1	LT1	
	3-21-2023 7:15:00 AM	LT1	LT1	
	3-28-2023 7:15:00 AM	LT1	LT1	
	4-4-2023 7:30:00 AM	LT1	LT1	
	4-11-2023 7:15:00 AM	LT1	LT1	
	4-18-2023 7:45:00 AM	LT1	LT1	
	4-25-2023 8:00:00 AM	LT1	LT1	
	5-2-2023 7:30:00 AM	LT1	LT1	
	5-9-2023 7:45:00 AM	QRWRT	QRWRT	
	5-16-2023 6:40:00 AM	LT1	LT1	
	5-23-2023 7:30:00 AM	LT1	LT1	
	5-30-2023 7:35:00 AM	LT1	LT1	
	6-6-2023 7:25:00 AM	LT1	LT1	

6-13-2023 7:00:00 AM	QRWRT	QRWRT	
6-20-2023 7:00:00 AM	LT1	LT1	
6-27-2023 7:30:00 AM	LT1	LT1	
7-4-2023 7:20:00 AM	LT1	LT1	
7-11-2023 7:15:00 AM	LT1	LT1	
7-18-2023 7:15:00 AM	LT1	LT1	
7-25-2023 7:30:00 AM	LT1	LT1	
8-1-2023 6:20:00 AM	LT1	LT1	
8-8-2023 7:20:00 AM	LT1	LT1	
8-15-2023 7:00:00 AM	LT1	LT1	
8-22-2023 7:30:00 AM	LT1	LT1	
8-29-2023 6:00:00 AM	LT1	LT1	
9-5-2023 7:15:00 AM	LT1	LT1	
9-12-2023 7:30:00 AM	LT1	LT1	
9-19-2023 7:30:00 AM	LT1	LT1	
9-26-2023 6:40:00 AM	LT1	LT1	
10-3-2023 7:30:00 AM	LT1	LT1	
10-10-2023 7:30:00 AM	LT1	LT1	
10-17-2023 7:15:00 AM	LT1	LT1	
10-24-2023 6:35:00 AM	LT1	LT1	
10-31-2023 7:00:00 AM	LT1	LT1	
11-7-2023 7:30:00 AM	LT1	LT1	
11-14-2023 7:15:00 AM	LT1	LT1	
11-21-2023 6:45:00 AM	LT1	LT1	
11-28-2023 6:45:00 AM	LT1	LT1	
12-5-2023 6:40:00 AM	LT1	LT1	
12-12-2023 6:45:00 AM	LT1	LT1	
12-19-2023 6:45:00 AM	<u>LT1</u>	<u>LT1</u>	
Total Positive:	0	0	0

Result Values:

E - estimated

L - less than

G - greater than

Samples that contain total coliform:	0	0.00% of total
Samples that contain e. coli:	0	0.00% of total
Samples that contain fecal coliform:	0	0.00% of total
Number of consecutive samples that contain total coliform:	0	
Number of samples that contain total coliform in last 30 days:	0/0	
Total number of samples:	51	

Comments:

Environmental Health Officer
Jan 24 2024

FOR FURTHER INFORMATION PLEASE CALL: Jessica Hibbs (604) 870-7900

Analytical Report

Bill To: Fraser Valley Regional District 1 - 45950 Cheam Ave. Chilliwack, BC, Canada V2P 1N6	Project ID: Canyon Chem/Phys Project Name: Canyon WS Project Location: Fraser Canyon LSD: P.O.:	Lot ID: 1724059 Control Number: Date Received: Apr 9, 2024 Date Reported: Apr 15, 2024 Report Number: 2991155 Report Type: Final Report
Attn: Accounts Payable Sampled By: Company: FVRD	Proj. Acct. code:	

Reference Number	1724059-1
Sample Date	April 09, 2024
Sample Time	06:45
Sample Location	
Sample Description	Hope Airpark / Hope Airport WS / 7.1 °C
Sample Matrix	Drinking Water

Analyte	Units	Result	Nominal Detection Limit	Guideline Limit	Guideline Comments
Metals Extractable					
Aluminum	Extractable mg/L	0.001	0.001	0.1 OG; 2.9 MAC	Below OG
Antimony	Extractable mg/L	0.00004	0.00002	0.006	Below MAC
Arsenic	Extractable mg/L	0.0002	0.0001	0.010	Below MAC
Barium	Extractable mg/L	0.013	0.0001	2.0	Below MAC
Boron	Extractable mg/L	0.009	0.002	5	Below MAC
Cadmium	Extractable mg/L	<0.00001	0.00001	0.007	Below MAC
Chromium	Extractable mg/L	0.00100	0.00005	0.05	Below MAC
Copper	Extractable mg/L	0.014	0.0005	1 AO; 2 MAC	Below AO
Lead	Extractable mg/L	0.00017	0.00001	0.005	Below MAC
Selenium	Extractable mg/L	<0.0002	0.0002	0.05	Below MAC
Strontium	Extractable mg/L	0.062	0.0001	7.0	Below MAC
Uranium	Extractable mg/L	0.00002	0.00001	0.02	Below MAC
Vanadium	Extractable mg/L	0.00023	0.00005		
Zinc	Extractable mg/L	0.013	0.0005	5.0	Below AO
Physical and Aggregate Properties					
Colour	True	Colour units	<5	5	
Turbidity		NTU	0.60	0.1	0.1/0.3/1.0 OG
Routine Water					
pH			7.17	0.01	7.0-10.5 Within Range
pH - Holding Time			Exceeded		
Temp. of observed pH		°C	21.4		
Electrical Conductivity	at 25 °C	µS/cm	124	1	
Calcium	Extractable	mg/L	14	0.01	
Iron	Extractable	mg/L	0.041	0.004	0.3 Below AO
Magnesium	Extractable	mg/L	3.3	0.02	
Manganese	Extractable	mg/L	0.001	0.001	0.02 AO; 0.12 MAC Below AO
Potassium	Extractable	mg/L	0.72	0.04	
Silicon	Extractable	mg/L	8.5	0.005	
Sodium	Extractable	mg/L	2.7	0.1	200 Below AO
T-Alkalinity	as CaCO3	mg/L	52	5	
Chloride	Dissolved	mg/L	3.10	0.05	250 Below AO
Fluoride	Dissolved	mg/L	<0.01	0.01	1.5 Below MAC
Nitrate - N	Dissolved	mg/L	0.46	0.01	10 Below MAC
Nitrite - N	Dissolved	mg/L	<0.01	0.01	1 Below MAC
Sulfate (SO4)	Dissolved	mg/L	3.2	0.1	500 Below AO
Hardness	as CaCO3 (extractable)	mg/L	49	1	
Total Dissolved Solids	Extractable	mg/L	84	1	500 Below AO