

Report For: Fraser Valley Regional District  
Received: 08/06/2026 11:50  
Report ID: 399L9537  
Report Name:

Sample ID: 399L9537\_X2778888  
Water System: Boston Bar Integrated  
Facility: Distribution  
Sampling Pt: Boston Bar #2/Highway 1 North (1-2-MD, 2C254)  
Comment: BOSTON BAR COMMUNITY WS, SAMPLE SITE 2 HWY 1  
Sampled: 08/04/2026

| MICROORGANISMS                      |                  | Criteria & Type |                          | Status |
|-------------------------------------|------------------|-----------------|--------------------------|--------|
| Escherichia coli / E. coli (counts) | < 1 counts/100ml | <=1,P           | Microbiological Standard | Final  |
| Total Coliforms (counts)            | < 1 counts/100ml | <=1,OG          | User-Defined             | Final  |

**Result Legend**

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no,  
TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment  
< means less than lower detection limit shown  
> means greater than upper detection limit shown  
« means detected & less than number shown  
» means detected & greater than number shown  
\* Indicates Criteria is exceeded